

## 2-wire programmable transmitter

### 6334B

- TC input
- High measurement accuracy
- Galvanic isolation
- Can be installed in Ex zone 0
- 1- or 2-channel version



















### Application


- · Linearized temperature measurement with TC sensor.
- Amplification of bipolar mV signals to a 4...20 mA signal, optionally linearized according to a defined linearization function.

#### **Technical characteristics**

- Within a few seconds the user can program PR6334B to measure temperatures within all TC ranges defined by the norms.
- · Cold junction compensation (CJC) with a built-in temperature sensor.
- · A limit can be programmed on the output signal.
- · Continuous check of vital stored data for safety reasons.

#### Mounting / installation

- · Mounted vertically or horizontally on a DIN rail. Using the 2channel version up to 84 channels can be mounted per meter.
- The 6334B can be mounted in zone 0, 1, 2 and zone 21, 22 including M1.



### Order

Туре	Version		Galvanic isolation	Channels	
6334	Zone 0, 1, 2, 21, 22, M1 / DIV. 1, DIV. 2	: B	1500 VAC	Single Double	: A : B

-40°C to +85°C -40°C to +85°C 2028°C < 95% RH (non-cond.) IP20
109 x 23.5 x 104 mm 145 / 185 g DIN EN 60715/35 mm 0.132.08 mm <sup>2</sup> AWG 2614
stranded wire 0.5 Nm
7.230 VDC ≤ 0.7 W/≤ 1.4 W (1 ch./2 ch.) 0.170.7 W
1.5 kVAC / 50 VAC
160 s
7.2 VDC
5 min.
Loop Link
Min. 60 dB Better than 0.05% of selected range
< 3.5 s
18 bit
16 bit
< 0.005% of span / VDC
< ±0.5% of span < ±1% of span
< ±1% of span
50% of selected max. value
B, E, J, K, L, N, R, S, T, U, W3, W5, LR
< ±1.0°C
-12150 mV
5 mV

# **Output specifications**

Current output	
Signal range	420 mA
Min. signal range	16 mA
Load (@ current output)	$\leq$ (Vsupply - 7.2) / 0.023 [ $\Omega$ ]
Sensor error indication	Programmable 3.523 mA
NAMUR NE43 Upscale/Downscale	23 mA / 3.5 mA
Common output specifications	
Updating time	440 ms
of span	= of the presently selected range

# Observed authority requirements

EMC	2014/30/EU & UK SI 2016/1091					
ATEX	2014/34/EU & UK SI 2016/1107					
RoHS	2011/65/EU & UK SI 2012/3032					
EAC	TR-CU 020/2011					
EAC Ex	TR-CU 012/2011					
Approvals ATEX DEKRA 20ATEX0095X						
IECEx						
ILOLX	DLR 20.0009X					