

# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20170505-E233311  
**Report Reference** E233311-20031111  
**Issue Date** 2017-MAY-05

**Issued to:** PR ELECTRONICS A/S  
LERBAKKEN 10  
8410 ROENDE DENMARK

**This is to certify that  
representative samples of**

PROCESS CONTROL EQUIPMENT FOR USE IN  
HAZARDOUS LOCATIONS

Associated apparatus, nonhazardous locations:  
Ex Solenoid / Alarm Driver Type 5203B followed by 1, 2, or  
3 followed by F, H or I Followed by 1 or 2, providing  
intrinsically safe outputs for use in hazardous locations  
Class I Division 1, Group A, B, C, and D, Class I Zone 0  
and 1, Group IIC, Class II, Division 1, group E, F, and G  
when installed in accordance with control drawing no.  
5203QU01.

Have been investigated by UL in accordance with the  
Standard(s) indicated on this Certificate.

**Standard(s) for Safety:**


UL913, Intrinsically Safe Apparatus and Associated  
Apparatus for use in Class I, II, and III Hazardous  
(Classified) Locations  
CAN/CSA C22.2 No. 157-92, Intrinsically Safe and Non-  
incendive Equipment for use in Hazardous Locations  
UL 508, Industrial Control Equipment

**Additional Information:**

See the UL Online Certifications Directory at  
[www.ul.com/database](http://www.ul.com/database) for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's  
Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program  
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please  
contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

