



IECEx Certificate of Conformity

INTERNATIONAL ELECTROTECHNICAL COMMISSION IEC Certification System for Explosive Atmospheres

for rules and details of the IECEx Scheme visit www.iecex.com

Certificate No.: **IECEx DEK 15.0039X** Page 1 of 4 Certificate history:
Status: **Current** Issue No: 3 Issue 2 (2016-01-26)
Date of Issue: 2020-01-07 Issue 1 (2015-09-29)
Issue 0 (2015-07-30)
Applicant: **PR electronics A/S**
Lerbakken 10
8410 Rønede
Denmark
Equipment: **Field mounted HART Temperature Transmitter, Type 7501A.....2. and Type 7501B.....2.**
Optional accessory:
Type of Protection: **Ex d, tb, ia, ic, nA**
Marking: Ex d IIC T6...T4 Gb
Ex tb IIIC T85 °C...T100 °C Db
Ex nA IIC T6...T4 Gc
Ex ia IIC T6...T4 Ga
Ex ia IIIC T60 °C...T100 °C Da
Ex ia I Ma (Stainless Steel version only)
Ex ic IIC T6...T4 Gc
Ex ic IIIC T85 °C...T100 °C Dc

Approved for issue on behalf of the IECEx
Certification Body:

R. Schuller

Position:

Certification Manager

Signature:
(for printed version)

Date:

1. This certificate and schedule may only be reproduced in full.
2. This certificate is not transferable and remains the property of the issuing body.
3. The Status and authenticity of this certificate may be verified by visiting www.iecex.com or use of this QR Code.



Certificate issued by:

DEKRA Certification B.V.
Meander 1051
6825 MJ Arnhem
Netherlands





IECEX Certificate of Conformity

Certificate No.: **IECEX DEK 15.0039X**

Page 2 of 4

Date of issue: 2020-01-07

Issue No: 3

Manufacturer: **PR electronics A/S**
Lerbakken 10
8410 Rønne
Denmark

Additional
manufacturing
locations:

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacturer's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEx Quality system requirements. This certificate is granted subject to the conditions as set out in IECEx Scheme Rules, IECEx 02 and Operational Documents as amended

STANDARDS :

The equipment and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards

IEC 60079-0:2011 Explosive atmospheres - Part 0: General requirements
Edition:6.0

IEC 60079-1:2007-04 Explosive atmospheres - Part 1: Equipment protection by flameproof enclosures "d"
Edition:6

IEC 60079-11:2011 Explosive atmospheres - Part 11: Equipment protection by intrinsic safety "i"
Edition:6.0

IEC 60079-15:2010 Explosive atmospheres - Part 15: Equipment protection by type of protection "n"
Edition:4

IEC 60079-31:2013 Explosive atmospheres - Part 31: Equipment dust ignition protection by enclosure "t"
Edition:2

This Certificate **does not** indicate compliance with safety and performance requirements other than those expressly included in the Standards listed above.

TEST & ASSESSMENT REPORTS:

A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in:

Test Report:

[NL/DEK/ExTR15.0050/05](#)

Quality Assessment Report:

[NL/DEK/QAR13.0017/04](#)



IECEx Certificate of Conformity

Certificate No.: **IECEx DEK 15.0039X**

Page 3 of 4

Date of issue: 2020-01-07

Issue No: 3

EQUIPMENT:

Equipment and systems covered by this Certificate are as follows:

The Field mounted HART Temperature Transmitter, Type 7501A.....2. and Type 7501B.....2., convert a temperature measurement signal into a 4 to 20 mA current signal, with digital communication (HART).

The transmitter, Type Type 7501A.....2., consists of an aluminium enclosure and Type 7501B.....2. consists out of a stainless steel enclosure, both with an internal temperature transmitter.

When delivered as a connection kit, the installer can build in his own transmitter, that is predefined by PR Electronics A/S. The transmitter is optionally supplied with an associated blanking element, Type 8550-... (M20) or Type 8551-... (1/2 NPT).

Optionally the transmitter has a glass window, a display and optical buttons to enable local interfacing.

The transmitter is intended, either to be connected via a cable, or to be mounted directly onto a temperature sensing probe that is suitable for the application and correctly installed.

For type of protection flameproof 'd', and dust ignition protection by enclosure 'tb', only IECEx equipment certified sensors, suitable for the application and correctly installed, may be mounted directly onto the Transmitter without additional certification of the combination.

If the transmitter is physically connected to a possible source of heating or cooling, e.g. by mounting to a process pipe or a temperature sensor, the temperature at the point of connection shall be within the ambient temperature range as given in this certificate.

For nomenclature, thermal and electrical data, see the Annex 1 to this certificate.

SPECIFIC CONDITIONS OF USE: YES as shown below:

For group III (dust), electrostatic charging of the paint layer shall be avoided.

For installation of Transmitter, Type 7501A.....2., as EPL Ga equipment, the transmitter must be installed such, that even in the event of rare incidents, ignition sources due to impact and friction, sparks are excluded.



IECEX Certificate of Conformity

Certificate No.: **IECEX DEK 15.0039X**

Page 4 of 4

Date of issue: 2020-01-07

Issue No: 3

DETAILS OF CERTIFICATE CHANGES (for issues 1 and above)

Minor constructional changes.

Annex:

[223963500-Annex1.pdf](#)

Annex 1 to IECEx test report NL/DEK/ExTR15.0050/05
Annex 1 to Certificate of Conformity IECEx DEK 15.0039X, issue 3
Annex 1 to EU Type Examination Certificate DEKRA 15ATEX0058 X, issue 4

Thermal and Electrical data

Type of protection Ex d:

U_{max} = 35 V.

Ambient temperature range:

- 40 °C to +70 °C for temperature class T6;
- 40 °C to +80 °C for temperature class T4 and T5 for Type 7501 B;
- 40 °C to +85 °C for temperature class T4 and T5 for Type 7501 A.

Type of protection Ex tb:

U_{max} = 35 V.

Ambient temperature range for Silicone rubber sealing-rings:

- 40 °C to +70 °C for maximum surface temperature T85 °C;
- 40 °C to +80 °C for maximum surface temperature T100 °C for Type 7501 B;
- 40 °C to +85 °C for maximum surface temperature T100 °C for Type 7501 A.

Ambient temperature range for FKM rubber sealing-rings:

- 20 °C to +70 °C for maximum surface temperature T85 °C;
- 20 °C to +80 °C for maximum surface temperature T100 °C for Type 7501 B;
- 20 °C to +85 °C for maximum surface temperature T100 °C for Type 7501 A.

Type of protection Ex ia and Ex ic:

Supply and output circuit (terminals 1, 2):

in type of protection intrinsic safety Ex ia I, Ex ia IIC, Ex ia IIIC, or Ex ic IIC, only for connection to a certified intrinsically safe circuit, with the following maximum values:

U_i = 30 V; I_i = 120 mA; P_i = 0.84 W; C_i = 2 nF; L_i = 0 μH.

Sensor circuit (terminals 3...6):

in type of protection intrinsic safety Ex ia I, Ex ia IIC, Ex ia IIIC, or Ex ic IIC, with following maximum values:

U_o = 9.6 V; I_o = 28 mA; P_o = 67.2 mW; C_o = 3.5 μF; L_o = 35 mH.

Although the sensor circuit is not infallibly galvanic isolated from the supply / output circuit, the galvanic isolation between the circuits is capable of withstanding a test voltage of 500 Vac during 1 minute.

Ambient temperature range for Ex ia:

- 40 °C to +45 °C for temperature class T6 or maximum surface temperature T60 °C;
- 40 °C to +60 °C for temperature class T5 or maximum surface temperature T75 °C;
- 40 °C to +80 °C for temperature class T4, maximum surface temperature T100 °C and Group I, for Type 7501 B;
- 40 °C to +85 °C for temperature class T4, maximum surface temperature T100 °C and Group I, for Type 7501 A.

Annex 1 to IECEx test report NL/DEK/ExTR15.0050/05
Annex 1 to Certificate of Conformity IECEx DEK 15.0039X, issue 3
Annex 1 to EU Type Examination Certificate DEKRA 15ATEX0058 X, issue 4

Ambient temperature range for Ex ic:

- 40 °C to +60 °C for temperature class T6 or maximum surface temperature T85 °C;
- 40 °C to +80 °C for temperature class T4 and maximum surface temperature T100 °C, for Type 7501 B;
- 40 °C to +85 °C for temperature class T4 and maximum surface temperature T100 °C, for Type 7501 A.

Type of protection Ex nA:

U_{max} = 35 V.

Ambient temperature range for Silicone rubber sealing-rings:

- 40 °C to +60 °C for temperature class T6;
- 40 °C to +80 °C for temperature class T4 for Type 7501 B;
- 40 °C to +85 °C for temperature class T4 for Type 7501 A.

Ambient temperature range for FKM rubber sealing-rings:

- 20 °C to +60 °C for temperature class T6;
- 20 °C to +80 °C for temperature class T4 for Type 7501 B;
- 20 °C to +85 °C for temperature class T4 for Type 7501 A.

Annex 1 to IECEx test report NL/DEK/ExTR15.0050/05
 Annex 1 to Certificate of Conformity IECEx DEK 15.0039X, issue 3
 Annex 1 to EU Type Examination Certificate DEKRA 15ATEX0058 X, issue 4

Nomenclature

7501	-	-	-	-	-	-	-	-
Type								
Housing A: Low copper Aluminium B: Stainless Steel								
Keypad Display 1: no no (window) 2: no yes 3: yes yes								
Sealing A: -40°C+85°C silicone rubber B: -20°C+85°C FKM rubber								
Conduit Threads 1: M20x1.5 6H 2: ½NPT mod								
Paint A: Epoxy B: Epoxy+Polyurethane N: None								
Transmitter 1: Yes 2: None (comes with a connection kit)								
Approvals 1: General purpose 2: Hazardous area								
Xtra None: standard X: Special edition The color of the front is normally Signal-Red but may be changed to any other color								