




	DK	UK	FR	DE
A	2-tråds Tx	2-wire Tx	Tx 2-fils	2-Draht Tx
B	Strøm, DC	DC current	Courant cc	DC-Strom
C	Spænding, DC	DC voltage	Tension cc	DC-Spannung
D	Potentiometer	Potentiometer	Potentiomètre	Potentiometer
E	RTD og lin. R	RTD and lin. R	RTD et R lin.	WTH und lin. R
F	TC	TC	TC	TE




	DK	UK	FR	DE
G	Speciel trig strøm & spænding	Special trig current & voltage	Déclenchement spécial courant & tension	Spezial Trig Strom und Spannung
H	TTL	TTL	TTL	TTL
I	SO	SO	SO	SO
J	NAMUR	NAMUR	NAMUR	NAMUR
K	PNP	PNP	PNP	PNP
L	NPN	NPN	NPN	NPN
M	Kontakt (NPN)	Contact (NPN)	Contact (NPN)	Schalter (NPN)
N	Tacho	Tacho	Tachy	Tacho



- DK Montering på DIN-skinne. Mounting on DIN rail.
- UK Montage sur rail DIN.
- FR Montage auf DIN-Schiene.



	DK	UK	FR	DE	4222	4225A	4225B	4225C
O	Frekvens udgang	Frequency output	Sortie fréquence	Frequenz- ausgang	x			
P	Strøm	Current	Courant	Strom		x		x
Q	Bufferet spænding	Buffered voltage	Tension direct	Gepufferter Spannung		x		x
R	2-tråds strøm	2-wire current	Courant 2-fils	2-draht Strom		x		x
S	Relæ 1	Relay 1	Relais 1	Relais 1			x	
S	Relæ 2	Relay 2	Relais 2	Relais 2		x	x	
T	Frekvens udgang	Frequency output	Sortie fréquence	Frequenz- ausgang				x



EU DECLARATION OF CONFORMITY (4222DoC\_103)



As manufacturer PR electronics A/S, Lerbakken 10, DK-8410 Rønde hereby declares that the following product:  
**Type:** 4222  
**Name:** Universal I/F converter  
**From serial no.:** 191015001  
 is in conformity with the following directives and standards:  
 The EMC Directive 2014/30/EU and later amendments  
**EN 61326-1 : 2013**  
 Immunity test requirements for equipment intended to be used in an industrial electromagnetic environment. For specification of the acceptable EMC performance level, refer to the electrical specifications for the device.  
 The Low Voltage Directive 2014/35/EU and later amendments  
**EN 61010-1 : 2010 + A1 : 2019**  
 The RoHS2 Directive 2011/65/EU and later amendments  
**EN IEC 63000 : 2018**  
 This declaration of conformity is issued under the sole responsibility of the manufacturer.

*Stig Lindemann*  
 Stig Lindemann, CTO  
 Manufacturer's signature

Rønde, 28 March 2022


EU DECLARATION OF CONFORMITY (4225DoC\_100)




As manufacturer PR electronics A/S, Lerbakken 10, DK-8410 Rønde hereby declares that the following product:  
**Type:** 4225  
**Name:** Universal I/F-I converter  
**From serial no.:** 201666001  
 is in conformity with the following directives and standards:  
 The EMC Directive 2014/30/EU and later amendments  
**EN 61326-1 : 2013**  
 Immunity test requirements for equipment intended to be used in an industrial electromagnetic environment. For specification of the acceptable EMC performance level, refer to the electrical specifications for the device.  
 The Low Voltage Directive 2014/35/EU and later amendments  
**EN 61010-1 : 2010 + A1 : 2019**  
 The RoHS2 Directive 2011/65/EU and later amendments  
**EN IEC 63000 : 2018**  
 This declaration of conformity is issued under the sole responsibility of the manufacturer.

*Stig Lindemann*  
 Stig Lindemann, CTO  
 Manufacturer's signature

Rønde, 28 March 2022




- DK Frigørelse fra DIN-skinne. Husk først at demontere tilslutningsklemmerne med farlig spænding. Modulet frigøres fra DIN-skinnen ved at løfte i den nederste lås.
- UK Demounting from DIN rail. First, remember to demount the connectors with hazardous voltages. Detach the device from the DIN rail by lifting the bottom lock.
- FR Démontage du rail DIN. Tout d'abord, n'oubliez pas de démonter les connecteurs ou régner des tensions dangereuses. Débloquez le verrou inférieur pour dégager le module du rail DIN.
- DE Lösen von DIN-Schiene. Zunächst ist gefährliche Spannung von den Anschlussklemmen zu trennen. Das Gerät wird von der DIN-Schiene gelöst, indem man den unteren Verschluss löst.



- DK Ledningskvadrat: 0.13...2.08 mm² / AWG 26...14 flerkoret ledning. Klemskruetilsætningsmoment 0,5 Nm.
- UK Wire size: 0.13...2.08 mm² / AWG 26...14 stranded wire. Screw terminal torque 0.5 Nm.
- FR Taille des fils: 0.13...2.08 mm² / AWG 26...14 fil multibrins. Pression max. avant déformation de la vis 0,5 Nm.
- DE Leitungsquerschnitt: 0.13...2.08 mm² / AWG 26...14 Litzen Draht. Klemmschraubenanzugsmoment 0,5 Nm.

- DK Montering af PR 4500-kommunikationsinterfacene:  
 1: Sæt tappene på PR 4500 ind i åbningerne i toppen af enheden.  
 2: Vip og klik PR 4500 på plads.  
 Afmontering af PR 4500-kommunikationsinterfacene:  
 3: Tryk på udløserknappen nederst på PR 4500, og vip PR 4500 op.  
 4: Med PR 4500 vippet op fjernes den fra åbningerne i toppen af enheden.




- UK Mounting of PR 4500 communications interface:  
 1: Insert the tabs of the PR 4500 into the slots at the top of the device.  
 2: Hinge the PR 4500 down until it snaps into place.  
 Demounting of the PR 4500 communication interfaces:  
 3: Push the release button on the bottom of the PR 4500 and hinge the PR 4500 out and up.  
 4: With the PR 4500 hinged up, remove from the slots at the top of the device.

- DE Montage der PR 4500-Kommunikations-schnittstellen:  
 1: Führen Sie die Laschen des PR 4500 in die Schlitzte an der Oberseite des Geräts ein.  
 2: Klappen Sie den PR 4500 herunter, bis er einrastet.  
 Demontage der PR 4500-Kommunikations-schnittstellen:  
 3: Drücken Sie den Entriegelungsknopf an der Unterseite des PR 4500 und klappen Sie das Gerät nach außen und oben.  
 4: Wenn der PR 4500 hochgeklappt ist, entfernen Sie ihn aus den Schlitzten an der Oberseite des Geräts.

- FR Montage de l'interface de communication PR 4500:  
 1: Insérez les languettes du PR 4500 dans les fentes situées en haut de l'appareil.  
 2: Rabattez le PR 4500 vers le bas jusqu'à ce qu'il s'enclenche en place.  
 Démontage de l'interface de communication PR 4500 :  
 3: Appuyez sur le bouton de déclenchement situé en bas du PR 4500 et faites pivoter le PR 4500 vers l'extérieur et vers le haut.  
 4: Le PR 4500 étant articulé, retirez-le des fentes situées en haut de l'appareil.

- DK Typenr.
- UK Type no.
- FR No. de type
- DE Typennr.

- DK Produktionsår fremgår af de to første cifre i serienummeret.
- UK Year of manufacture can be taken from the first two digits in the serial number.
- FR L'année de production est définie grâce aux deux premiers chiffres du numéro de série.
- DE Die ersten beiden Ziffern der Seriennummer geben das Produktionsjahr an.



- DK Benforbindelser
- UK Pin connections
- FR Raccordement des bornes
- DE Klemmenanschluss
- DK Godkendelser
- UK Approvals
- FR Homologations
- DE Zulassungen

Part Name	Hazardous Substances					
	Lead (Pb)	Mercury (Hg)	Cadmium (Cd)	Hexavalent Chromium (Cr (VI))	Polybrominated biphenyls (PBB)	Polybrominated diphenyl ethers (PBDE)
Printed circuit board	X	0	0	0	0	0

This table is prepared in accordance with the provisions of SJ/T 11364  
 O: Indicates that said hazardous substance contained in all of the homogeneous materials for this part is below the limit requirement of GB/T 26572.  
 X: Indicates that said hazardous substance contained in at least one of the homogeneous materials used for this part is above the limit requirement of GB/T 26572.

The product's Environmentally Friendly Use Period (EFUP) is 50 years